

HEALTH AND HYGIENE CERTIFICATE

I paid a visit to Comet Mensa Public School, Village Dehri, Post office Kuthandal, Tehsil Fatehpur, District Kangra Himachal Pradesh - 176022 on 02.01.2026. at 12:00 P.M. The Health and Sanitary provisions in the school premises were found to be satisfactory and well taken care of in every respect.

Dated 20.01.2026

Senior Medical Officer

Civil Hospital Rehan
Senior Medical Officer
Civil Hospital Rehan
Teh. Fatehpur (Kangra) H.P.


Annexure C

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No.-1612

Dated: 6/03/26

It is certified that an inspection team headed by Er. Amit Randhawa (Name of Officers with Designation) Inspected the **Comet Mensa Public School Dehri** (Name & Address of the school) on **03-03-2026** (date of inspection) and on the basis of Water Test Report (Attached) of **Jal Shakti Sub Division Fatehpur** (PHED Lab), Certified that the **Comet Mensa Public School Dehri** (Name of School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/State/UT Govt.


Assistant Engineer
Jal Shakti Sub Division
Raja Ka Talab

Signature with Seal:.....

Name : Amit Randhawa

Designation : Assistant Engineer

JSV Sub Division Raja Ka Talab

To

Comet Mensa Public School, Dehri

.....
(Name & Address of the Institution)

HIMACHAL PRADESH JAL SHAKTI VIBHAG
WATER TESTING LABORATORY DIVISION FATEHPUR

No.AE/JSV/FTR/Water Sample/2025 -2877

Dated:-3/3/26

Collected By Madan Lal

On Dated 2/03/2026

Date of Result:-3/03/2026


Source Private Tap

Location Comet Mensa Public School, Dehri

Limits: Based upon BIS : 10500-2012

PHYSICAL PARAMETERS					
S.No.	Parameter	Unit	Acceptable Limit	Permissible Limit	Result
1	Temperature	Celsius	18°C
2	Colour	Hazen Unit	5	15	5
3	Odour	Agreeable	Agreeable	Agreeable
4	Taste	Agreeable	Agreeable	Agreeable
5	Turbidity	NTU	1	5	4
6	PH	6.5-8.5	No Relaxation	7.45
CHEMICAL PARAMETERS					
7	TDS/Electrical Conductivity	Mg/l	500	2000	170
8	Total Hardness	Mg/l	200	600	290
9	Total Alkalinity	Mg/l	200	600	220
10	Chloride	Mg/l	250	1000	150
11	Calcium	Mg/l	75	200	60
12	Magnesium	Mg/l	30	100	23
13	Nitrate	Mg/l	45	No Relaxation	Nil
14	Iron	Mg/l	1	No Relaxation	Nil
15	Maganese	Mg/l	0.1	0.3	-
16	Sulphate	Mg/l	200	400	-
17	Fluoride	Mg/l	1	1.5	-
18	Free Residual Chlorine	Mg/l	0.2	1	0
BACTERIOLOGICAL PARAMETERS					
19	Total Coliforms	MPN/100MI	Nil	Nil	Nil
20	E-Coli/Thermo Tolerant Coliforms	MPN/100MI	Nil	Nil	-

This Water is safe for Drinking Purpose


Assistant Chemist
Jal Shakti Vibhag
Water Testing Laboratory, Fatehpur


Assistant Engineer
Jal Shakti Vibhag
Sub Division Fatehpur